



Brisbane City Council
ABN 72 002 765 795

Natural Environment & Sustainability
City Policy & Strategy Division
Level 7, Brisbane Square
266 George Street
GPO Box 1434
Brisbane Qld 4001

10 January 2007

Telephone: (07) 340 35231
Facsimile: (07) 340 39072
E-mail: paul.magee@brisbane.qld.gov.au

Mr Grant Breeze
Store-Safe
PO Box 5526
Alexandra Hills 4161

Dear Mr Breeze

DANGEROUS GOODS SAFETY MANAGEMENT REGULATIONS 2001
Application for Generic Design Approval for Flameproof Cabinets

Applicant/Manufacturer: Store-Safe		
Model Name: IFS Indoor Flammable Store		
Model Type	Maximum Storage Capacity (litres)	Drawing Nos:
IFS 450	450	<ul style="list-style-type: none"> • IFS 450-02 • IFS Bund 450ASSY
IFS 650	650	<ul style="list-style-type: none"> • IFS 650-02 • IFS Bund 04.DWG
IFS 850	850	<ul style="list-style-type: none"> • IFS 850-03 • IFS Bund ASSY

Reference is made to your e-mail of 7 August 2006 applying for generic design approval for Store-Safe's range of "IFS Indoor Flammable Liquids Stores" (flameproof storage cabinets). Please be advised that the specific design of this series of flameproof storage cabinets has been approved, **as per the attached plans**, for the storage of flammable and combustible liquids within the City of Brisbane pursuant to the *Part 4, Dangerous Goods Safety Management Regulation 2001*. Modifications to these designs are not permitted under this approval unless permission is obtained from this Branch.

Please ensure that a copy of this approval letter is supplied with each cabinet and that the customer is advised that cabinets

- must not be modified without approval
- must be located and used in compliance with AS1940
- and that a Licence for the Storage of Flammable and Combustible Liquids will be required from Brisbane City Council where quantities exceed those in Table 2.1 AS1940.

Should you require further information on this matter, please contact this office on ph. (07) 3403 5231.

Yours sincerely



Paul Magee
Senior Policy Officer - Dangerous Goods
POLLUTION PREVENTION TEAM