



ABN 35 002 864 002

Commercial Fuel Installations and Pump Maintenance | Facilities and Plant Engineering | Dangerous Goods Storage Consultants

22nd October, 2008

Store-Safe Pty Ltd
71-73 Lords Road
Leichhardt, NSW 2040

Att:- Mr Grant Breeze

Dear Sir,

Re: Portable Gas Gage Design and Construction Compliance Review

Thank you for choosing Petrolink to conduct a compliance review of the Store-Safe portable gas cage.

This design and construction audit relates only to the Store-Safe Portable Gas Cage as depicted on Drawing No OFG/1 dated 16/4/93 and OFG-D/02 dated 1/8/93. The primary purpose of the Portable Gas Cage is for the safe and secure storage of gases in cylinders, including aerosol cans.

I have found that the Gas Cage shown complies with the requirements of Australian Standards AS4332-2004 Storage of Gases in Cylinders, AS5601-2004 Gas Installations and AS1170-2002 for Structural Design and have Stamped the relevant Plans accordingly.

Yours sincerely,

Barry Boné AMS (Grad) AIDGC
Director
Accredited Dangerous Goods Consultant

