



Risk assessment checklist

- Section A Mandatory, not normally variable (eg location)
- B Mandatory, variable
- C Blank boxes for additional requirements specified by user's risk assessment

	Item to be checked	Correct & date	If not correct what action is required	Now correct & date
A1	Location correct in all details as specified on safety label			
B1	Spillage compound empty, dry and clean			
B2	No ignition sources in cabinet			
B3	No ignition sources within 3 m radius to height 1 m above door			
B4	Doors close quickly and never leave any gap			
B5	Spill kit within 3 m radius and fully stocked			
B6	Fire Extinguisher within 3 m to 10 m radius			
C1	Fewer than 10 spraypaint cans in cabinet			
C2	No glass bottles in cabinet			
C3	No strong solvent smell in or near cabinet			
C4	No mixed classes of substances in cabinet			
C				
C				
C				
C				
C				
C				
C				

Checklist inspection carried out by: _____

Store-Safe, PO Box 75 LEICHHARDT NSW 2040 Phone (Head office) 02 9569 2122 Fax 02 9568 3313

The information contained in this 'Risk assessment checklist' is merely to provide general guide on Store-Safe's products. Before a decision is made by you to use this checklist, Store-Safe recommends that you contact a Dangerous Goods Consultant or relevant government authority to discuss what suits your needs.